

## DECLARATION OF CONFORMITY NO. 216/03/2013

1. Seat: **ALNOR-SYSTEMY WENTYLACJI SP. Z O.O.**  
**00-719 Warszawa, ul. Zwierzyniecka 8b, POLAND**  
**Tel.: + 48 22 737 40 00, Fax.: + 48 22 737 40 04**  
  
Manufacturer: **ALNOR-SYSTEMY WENTYLACJI SP. Z O.O.**  
**05-552 Wola Mrokwoska, Aleja Krakowska 10, POLAND**
2. Name of building product: **Access door for round ducts, IPR**
3. Destination and range of use of product: **Mounting on round ducts in ventilation installations in buildings**
4. Technical Specifications:  
**EN 12097:2006 Ventilation for buildings - Requirements for ductwork components to facilitate maintenance of ductwork systems**  
**EN 12237:2003 Ventilation for buildings - Ductwork – Strength and leakage of circular sheet metal ducts**  
**Technical catalogue Alnor Systemy Wentylacji Sp. z o.o.**
5. Declared characteristic of product:  
**According to technical specification**  
**Steel tape galvanized on both sides according to the standard EN 10346:2009**  
**Tightness – Class D**
6. Name of Notified Body and no. of approval: **Swedish Institute for Technical Approval in Construction, Swedish Technical Approval no. 0103/07**

We declare under our sole responsibility that building product is in conformity with technical specification indicated in point 4.

Wola Mrokwoska 06.03.2013

.....  
Date and place of issue of declaration

*Zbigniew Jędraszk*  
.....  
Signature

ALNOR-SYSTEMY WENTYLACJI Sp. z o.o.  
ul. Zwierzyniecka 8b, 00-719 Warszawa  
tel. +48 22 737 40 00 fax. +48 22 737 40 04  
NIP: 521-10-63-747, REGON: 010685817