



Our company, „Komfovent“ UAB (company code: 124130658, Lentvario str. 146, Vilnius, Lithuania) hereby confirms that the combined purpose equipment for ventilation, air conditioning, heating system and domestic hot water preparation identified as **KOMBI** are designed and produced according to these European Union regulations where applicable:

- Machinery directive **2006/42/EC**;
- EMC directive **2014/30/EU**;
- Low voltage directive **2014/35/EU**;
- Pressure equipment directive **2014/68/EU**;
- RoHS directive **2011/65/EU**;
- WEEE directive **2012/19/EU**;
- Ecodesign directives **2009/125/EU** and **(EU) 2017/1369** following regulations:
 - Ecodesign requirements for ventilation units No. **1253/2014**;
 - Energy labelling of residential ventilation units No. **1254/2014**.

The following standards are applied in applicable parts:

- **EN ISO 12100:2010** *Safety of machinery – General principles for design – Risk assessment and risk reduction*;
- **EN IEC 61000-6-3:2021** *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial environments*;
- **EN 60335-1:2012 + AC:2014 + A11:2014 + A13:2017 + A1:2019 + A2:2019 + A14:2019 + A15:2021** *Household and similar electric appliances – Safety – Part 1: General requirements*;
- **EN 60335-2-40:2023 + A11:2023** *Household and similar electrical appliances – Safety – Part 2-40: Particular requirements for electrical heat pumps, air-conditioners and dehumidifiers*;
- **EN 1886:2007** *Ventilation for buildings – Air handling units – Mechanical performance*;
- **EN 308:2022** *Heat exchangers. Test procedures for establishing performance of air to air and flue gases heat recovery devices*;
- **EN 13142:2021** *Ventilation for buildings – Components/products for residential ventilation – Required and optional performance characteristics*;
- **EN 13141-7:2021** *Ventilation for buildings – Performance testing of components/products for residential ventilation – Part 7: Performance testing of a mechanical supply and exhaust ventilation units (including heat recovery) for mechanical ventilation systems intended for single family dwellings*;
- **EN 14511-2:2022** *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors – Part 2: Test conditions*.



- **EN 14511-4:2022** *Air conditioners, liquid chilling packages and heat pumps for space heating and cooling and process chillers, with electrically driven compressors – Part 4: Requirements.*
- **EN 14825:2022** *Air conditioners, liquid chilling packages and heat pumps, with electrically driven compressors, for space heating and cooling, commercial and process cooling – Testing and rating at part load conditions and calculation of seasonal performance.*

Declaration is only valid for the air handling units mounted according to installation manuals provided by manufacturer and to the ones that has no constructional changes applied by third parties unless necessary changes are agreed with manufacturer in advance.

We are a certified company, which meets the requirements of the following standards:

- **ISO 9001:2015** *Quality management systems - Requirements;*
- **ISO 14001:2015** *Environmental management systems – Requirements with guidance for use.*

Declaration compiled by:

Head of Technical department

Julius Šiaudvytis

Signed by:

Technical Director

Sigitas Juraitis

Plant Manager

Ramūnas Graužinis

2024-11-12, Vilnius, Lithuania