

DECLARATION OF CONFORMITY NR 063/01/2011

1. Manufacturer: **AFS IVEDIK ORGANIZE SANAYI BÖLGESİ**
1468, Cadde No: 153 Ostim/Ankara Turcja
Tel. +90 312 395 48 60, fax. +90 312 395 48 68

Distributor: **ALNOR-SYSTEMY WENTYLACJI SP. Z O.O.**
00-719 Warszawa ul. Zwierzyniecka 8b POLSKA
Tel.: + 48 22 737 40 00, Fax.: + 48 22 737 40 04
2. Name of building product: **Insulated flexible duct, SONODUCT AD-L**
3. Destination and range of use of product: **Ventilation and air conditioning installations in buildings**
4. Technical specification:
EN 13180:2004 Ventilation for buildings – Ductwork – Dimensions and mechanical requirements for flexible ducts
5. Declared characteristic of product:
According technical specification:
Duct: Perforated M1+ polyester foil,
Jacket: Alu-polyester foil M1,
Thickness of insulation: 25 mm,
Length: 10 mb,
Temperature: max 140° C

We declare under our sole responsibility that building product is in conformity with technical specification indicated in point 4.

Wola Mrokowska, 26.01.2011

.....
Date and place of issue of declaration

.....
Signature

ALNOR-SYSTEMY WENTYLACJI Sp. z o.o.
ul. Zwierzyniecka 8b, 00-719 Warszawa
tel. +48 22 737 40 00, fax. +48 22 737 40 04
NIP: 521-10-68-747, REGON: 010685817