

## DECLARATION OF PERFORMANCE

**No 069/07/2017**

1. Unique identification code of the product:

**Suspension ring for ventilation ducts: CLRL/CLR**

2. Intended use:

**For ductwork hangers and supports in ventilation and air conditioning installations in buildings.**

3. Manufacturer:

**Alnor Systemy Wentylacji Sp. z o.o.  
00-719 Warszawa ul. Zwierzyniecka 8b  
Tel.: + 48 22 737 40 00, Fax.: + 48 22 737 40 04**

4. Agent:

**Not relevant**

5. System of AVCP:

**System 4**

6. Standard:

**EN 12236:2003 Ventilation for buildings – Duct hangers and supports – Requirements for strength**

7. Notified body:

**Technical Recommendation RT ITB-1112/2017 issued by the BUILDING RESEARCH INSTITUTE, ul. Filtrowa 1, 00-611 Warsaw, Poland. Date of issue: 13.10.2017**

8. Declared performances:

Essential Characteristics	Declared performances	Notes
Diameter range	80 – 1600 mm	

Design load-carrying capacity	DN80-140: 0,45 kN DN150-200: 0,38 kN DN224-315: 0,36 kN DN355-400: 0,32 kN DN450: 0,42 kN DN500-1600: 0,40 kN	
Thickness	2,0 – 2,5 mm	
Tolerance for dimensions	Corresponds with requirements	
Appearance and quality	Corresponds with requirements	

9. The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer:

Artur Kołacz

Product Manager

.....  
(Name and position)

Wola Mrokwowska 28.11.2017

.....  
(Place and date of issue)

  
ALNOR-SYSTEMY WENTYLACJI Sp. z o.o.  
ul. Zwierzyniecka 8B, 00-719 Warszawa  
tel. +48 22 737 40 00, fax. +48 22 737 40 04  
NIP: 521-10-68-747, REGON: 010685817  
(Signature)