

No. JSSR-DOP023002-202

1. Unique identification code of the product-type:
*rectangular air dampers (SRC),
rectangular shut-off dampers (SRU, SRT).*
2. Type, batch or serial number or any other element allowing identification of the construction product:
SR[C, T, UJ]-[R, MJ]-[100-2400]x[100-2100].
3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
products' purpose is to control the opening for the ventilation system.
4. Name, registered trade name or registered trade mark and contact address of the manufacturer:
UAB "Komfovent", company code 124130658, Ozo str. 10, Vilnius, Lithuania, phone +370 (5) 2779701, info@komfovent.com.
5. Name and contact address of the authorized representative whose mandate covers the tasks:
NPD.
6. System or systems of assessment and verification of constancy of performance of the construction product:
System 4.
7. Name and identification number of the notified body:
NPD.
8. Name and identification number of the Technical Assessment Body:
NPD.
9. Declared performance:

Main characteristics	Performance	Technical specification
Leakage class for SRU and SRT	Class 2	EN 1751:2014 Ventilation for buildings – Air terminal devices – Aerodynamic testing of damper and valves



Leakage class for SRC	Class 0	EN 1751:2014 Ventilation for buildings – Air terminal devices – Aerodynamic testing of damper and valves
Leakage class for casing (SRC, SRU, SRT)	Class C	EN 1751:2014 Ventilation for buildings – Air terminal devices – Aerodynamic testing of damper and valves
Dimensions for dampers with rectangular cross-section		EN 1505:1997 Ventilation for buildings – Sheet metal air ducts and fittings with rectangular cross section - Dimensions
<i>The declaration is only valid for the dampers installed according to the manufacturers' instructions.</i>		

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed:

Head of Technical department

Julius Šiaudvytis

[Signature]
2020-12-15, Vilnius

