\_\_\_

1 page of 2

## No. JSSTS-DOP027003-211

- 1. Unique identification code of the product-type: *Sound attenuators.*
- 2. Type, batch or serial number or any other element allowing identification of the construction product:
  - STS[C, N]P-[100-200]-[100-250]-[300-2200]-[300-1500]-[300-2000]-[, D, M, S, W].
- 3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer: *Products' purpose is to reduce the noise emissions inside the ventilation system.*Sound attenuators may be exploited only according to manufacturer's instructions.
- 4. Name, registered trade name or registered trade mark and contact address of the manufacturer:
  - UAB "Komfovent", company code 124130658, Ozo str. 10, Vilnius, Lithuania, phone +370 (5) 2779701, info@komfovent.com.
- 5. Name and contact address of the authorized representative whose mandate covers the tasks:

NPD.

- System or systems of assessment and verification of constancy of performance of the construction product:
   System 4.
- 7. Name and identification number of the notified body: *NPD*.
- 8. Name and identification number of the Technical Assessment Body: *NPD*.
- 9. Declared performance:

| Main characteristics  | Performance  | Technical specification   |
|---|--|---|
| STSCP sound<br>attenuators are<br>made of galvanized<br>steel | DX51D+Z275<br>(chemical passivation.<br>Zinc thickness 275 g/m²) | EN 10346:2015 Continuously hot-dip coated steel flat products - Technical delivery conditions |







2 page of 2

| STSNP sound<br>attenuators are<br>made of stainless<br>steel | AISI 304 | <b>EN 10088-2:2014</b> Stainless steels  - Part 2: Technical delivery conditions for sheet/plate and strip of corrosion resisting steels for general purposes |
|--|----------|---|
| Anticorrosion<br>class                                       | C class  | EN ISO 12944-5:2019 Paints and varnishes - Corrosion protection of steel structures by protective paint systems - Part 5: Protective paint systems            |
| Leakage class  | C class  | <b>EN 1507:2006</b> Ventilation for buildings – Sheet metal air ducts with rectangular section – Requirements for strength and leakage                        |

The declaration is only valid for the products installed according to the manufacturers' instructions.

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Declaration compiled by:

Signed:

Head of Technical department

Julius Šiaudvytis

**Technical Director** 

Sigitas Juraitis

Plant Manager

Ramūnas Graužinis

2021-05-12, Vilnius

CE



